

# Energy Reduction Analysis at New Prague Wastewater Treatment Facility

Emily Wen

MnTAP advisor: A.J. Van den Berghe

On-Site Supervisor: Scott Warner



UNIVERSITY OF MINNESOTA

**Driven to Discover**<sup>SM</sup>

# Minnesota Technical Assistance Program

- Created in 1984
- University of Minnesota
- Staffed by Scientists and Engineers
- Process Specific Assistance
- Confidential and Non-regulatory



# MnTAP Mission

**Strengthening Minnesota businesses by improving efficiency, while saving money through energy, water and waste reduction.**

- **Businesses remain competitive**
- **Improve employee and public health**
- **Protect the environment**

# MnTAP Services

- **Technical Assistance**
  - Site assessment visits
  - Phone and e-mail requests
  - Intern program
  - Demonstrations/Research
- **Minnesota Materials Exchange**
- **Communications and Outreach**






# Company Overview

- Remove contaminants from wastewater
- 7,700 residents
- Regulated by Minnesota Pollution Control Agency
- Class A wastewater facility
- Upgraded in 2010
- Many energy savings ideas implemented, knew of more opportunities but unsure how to proceed



# City of New Prague Wastewater Plant Flow Diagram



# Incentives to Change

- **Operating budget covered by water and sewage fees**
  - Have exceeded budget
  - Excess covered in city taxes
- **Next MPCA permit may include more requirements**
  - Require additional equipment
  - Minimize energy increase with optimizing
- **SMMPA and MnTAP reached out to us to partner in energy savings**
- **St. Peter, MN had a successful project in 2016**



# Project Overview

## 1. Characterize energy consumption plant-wide

- Identify energy-intensive equipment
- Observe yearly consumption trends

## 2. Quantify scrubber/HVAC reductions

- Determine suitable # air changes per hour (ACH)
- Predict savings for reduced exhaust fan speeds

## 3. Assess Biological Aerated Filter (BAF) blower reduction




- Dissolved oxygen aeration model

## 4. Ultrasonic leak study

- Find compressed air leaks

## 5. Lighting audit

- Determine suitable LED replacements and resulting savings






# EPA Energy Assessment Tool

- Track energy usage for small wastewater facilities
  - Excel spreadsheet
- Method:
  - Collect utility bills from 2014-2017
  - Collect motor specification data
- Focus on electricity reduction

Utility	Site Utility Use	Site Utility Costs	% of Costs
Electricity	2,183,200 kWh	\$166,663	76%
Natural Gas	79,167 CCF	\$48,180	22%
Water & Sewer	870,000 GAL	\$4,100	2%


**\$718/MGAL Treated**

# Top Electrical Energy Use Systems




- #1 Odor Control
- #2 Sludge Handling
- #3 BAF Treatment
- #4 Non-process HVAC
- #5 Internal Plant Pumping
- Balance of Plant Identified
- Balance of Plant Unidentified


# Quantify scrubber/HVAC reductions



# Odor Scrubbers



<u>Room</u>	<u>Air changes per hour</u>
BAF	7.2
Pretreatment	4.8
Biosolids	4.0





# Option 1.1: 7.2 to 4.9 ACH → Implemented

ACH	Annual Energy Consumption	Annual Operating Cost
7.2	156,490 kWh 536 therms	\$11,900 \$332
4.9	50,3034 kWh 383 therms	\$3,825 \$240

**Savings**

106,000 kWh  
150 therms

\$8,100

# Option 1.2: Switch fans and reduce to 4.9 ACH

Swap biosolids and BAF scrubber fan

- Reduce fan flow rate from 7,600 to 5,283 ACFM

ACH	Annual Energy Consumption	Annual Operating Cost
4.9	102,618 kWh	\$7,800

**Savings**

21,035 kWh

\$1,600

# Option 1.2: Further investigation/not recommended

- BAF and biosolids odor scrubbers are different models
  - Undetermined volumetric capacities
- Undetermined labor costs
  - Likely a week
- Requires further investigation by Evoqua engineers




Biosolids scrubber fan



BAF scrubber fan

# Assess BAF Blower Reduction






# Biological Aerated Filter (BAF)

- **Secondary treatment**

- Removes total suspended solids (TSS), ammonia, and carbonaceous biological oxygen demand

- **Microbes require oxygen**

- 0.5-2 mg/L dissolved oxygen (DO)



BAF schematic by Veolia/Kruger

# Option 2.1: Adjust controls settings

- Reduces blower operating hours
- Optimal set point at 1.5 gallons per minute per sqft

Influent Load Control

Constant Number Of Cells In Filtration

Number Of Cells In Filtration:	1	4 Ea.	4	
<input checked="" type="radio"/> Constant Load	Biostyr Filter Velocity 1:	0	1.5 GPM/Ft <sup>2</sup>	4
	Minimum Number Of Cells:	1	1 Ea.	4
	Maximum Number Of Cells:	1	4 Ea.	4

New Prague SCADA set point screen shot

# Option 2.1: Adjust SCADA settings → Implemented

Condition	Annual Energy Consumption	Annual Operating Cost
2016 Baseline (min. 2 cells, TCV=1.0 gpm/sqft)	385,300 kWh	\$29,283
2017 Baseline (min 1 cell, TCV=1.5 gpm/sqft)	237,693 kWh	\$18,065

**Savings**

148,000 kWh

\$11,200

## Option 2.2: Install VFDs to BAF Blowers → Recommended


- Reduces power consumption during operation
- Eliminate inrush
  - Reduces electric costs
  - Increase blower lifespan



Allen Bradley PowerFlex 753, the proposed VFD for installation



# Option 2.2: Install VFDs to BAF Blowers



## Option 2.2: Install VFDs to BAF Blowers

Condition	Annual Energy Consumption	Annual Operating Cost
2017 Baseline (min 1 cell, TCV=1.5 gpm/sqft)	237,693 kWh	\$18,100
4.0 mg/L target DO	130,560 kWh	\$9,922

**Savings**


107,000 kWh

\$8,142

# New Prague Effluent Requirements

Parameter	Limit (mg/L)	Limit Type	Effective Period
Dissolved Oxygen (DO)	7	Calendar Month Minimum	Jan-Dec
Carbonaceous Biological Oxygen Demand (CBOD), 05 Day	5	Calendar Month Average	Jan-Dec
Nitrogen, Ammonia, Total	7.7	Calendar Month Average	Dec-Mar
Nitrogen, Ammonia, Total	1.3	Calendar Month Average	Apr-May
Nitrogen, Ammonia, Total	1.0	Calendar Month Average	Jun-Sep
Nitrogen, Ammonia, Total	1.9	Calendar Month Average	Oct-Nov
Total Suspended Solids (TSS)	30	Calendar Month Average	Jan-Dec

# Ultrasonic Leak Study



# 8 Leaks Found













Photo credit: Marcus Hendrickson



# 6 Additional Leaks Found



# Option 3.1: Seal compressor leaks

Condition	Annual Energy Consumption	Annual loss
8 leaks	13,820+ kWh	\$1,050+

- **Status: In progress**
  - 9 leaks fixed
  - \$827+ saved annually
- **Implementation Cost**
  - \$220



# Lighting Audit



# LED Technology Constantly Improving


- **New Prague WWTF lighting**
  - 112 lights are on 24/7
- **LED refits**
  - Longer lifespan (50,000 hours)
  - Lower power consumption (18 watt)
  - Compatible with ballasts



LED exterior fixture in progress of installation



Main hall lighting



Stairwell lighting

# Option 4.1: Upgrade lights to LED

Condition	Annual Energy Consumption	Annual Operating Cost
Fluorescent/MH/HPS	70,268 kWh	\$5,340
LED	41,654 kWh	\$3,165

**Savings**

28,613 kWh

\$2,175



# Potential Savings Summary

Recommendations	Annual Reduction	Implementation Cost	Annual Savings	Payback Period	Status
Reduce ACH to 4.9	106,000 kWh 150 therms	\$0	\$8,100	-	Implemented
SCADA change and reduce DO to 4.0 mg/L using VFD	254,740 kWh	TBD	\$19,300	4-5 years	Recommended
Seal leaks	13,820 kWh	\$220	\$1,050+	2.6 months	In Progress
Upgrade to LED	28,600 kWh	TBD	\$2,100	2-3 years	Recommended
<b>Totals</b>	<b>403,000 kWh 150 therms</b>	<b>TBD</b>	<b>\$30,550</b>	<b>TBD</b>	<b>-</b>

# Future recommendations

- **Reduce scrubber and make-up air unit to 4.0**
  - Reduces 125,000 kWh and \$9,500
- **Study VFD installation on main lift station pump effects**
  - Eliminate inrush throughout facility
  - More efficient chemical feed
  - Prolong motor life
- **Sludge aeration blower**
  - Possible upgrades and installations
  - Contacted Aeration Industries International



# Special thanks to the following

**AJ Van den Berghe**

**Scott Warner**

**John Granlund**

**Adam Jirak**

**Joe Wagner**

**Nathan Landwehr**

**Marcus Hendrickson**

**Kim Lee**

**Lora Novotny**

**Jon Peterson**

**Doug Swanson**

**Devang Pujara**

**Daryl Bond**

**Mark Drake**

**Ryan Cairl**

**Jon Vanyo**

**Randy Keranen**

**Daryld Miller**

**Chad Lunder**

**Eric Bennett**

**Jeff Boumeester**

**Bruce Stasney**

# Thank you for listening!

Questions?



This project was funded in part by Southern Minnesota Municipal Power Agency